



Proposed Code Change

State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received

Code 62.7-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – Dashed line through material to be deleted, underline material to be added)

Use second sheet for any material requiring more space.

Code Title Indiana Residential Code		Edition 2009
Section number and title E3907.2 Exception		Page 699 & 700
Proponent Charlie Eldridge	Title Consultant	
Address 551 Grassy Ln., Indianapolis, IN 46217		Phone (317) 370-3444
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input checked="" type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>E3907.2 Damp and wet locations. In damp or wet locations, cabinets and panelboards of the surface type shall be placed or equipped so as to prevent moisture or water from entering and accumulating within the cabinet, and shall be mounted to provide an airspace not less than 1/4 inch (6.4 mm) between the enclosure and the wall or other supporting surface. Cabinets installed in wet locations shall be weatherproof. For enclosures in wet locations, raceways and cables entering above the level of uninsulated live parts shall be installed with fittings listed for wet locations.</p> <p><u>Exception: Nonmetallic enclosures shall be permitted to be installed without an airspace on a concrete, masonry, tile, or similar surface.</u></p>		
REASON AND FISCAL IMPACT		
This text was extracted from the 2005 Indiana Residential Code.		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		